

THE ADMINISTRATION OF UNION TERRITORY OF LADAKH

OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH

(e-mail-igp-ladakh@police.ladakh.gov.in)

(Office Phone No: 01982-260888) No: F&ES/Dir/NOC/2023- 2-155-56 Dated: 08/05/2023

Subject: Fire NOC of Ladakh Rigjung Public School Choglamsar, Leh.

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the school which has been done by DFO Fire and Emergency Services, Leh. The detailed report is as under:

Location/ Accessibility:

The school building is constructed at Choglamsar, Leh. It is located at Longitude 77.592337 and Latitude 34.112821. The site is approximately 08 Kms from Fire and Emergency Services Station, Leh. It takes approximately 13 minutes to reach the site and is approachable for fire appliances.

Detail of building:

The school building has 07 blocks. The detailed of the block is as under:

1st block: It is three storied building having two staircases. In the ground floor there are 15 number of class rooms. One window in each class room and the size is 7x6 feet. Two side of the windows have provision to open. 1st floor has 13 rooms using as hostel. The corridor size is 6 feet. 2nd floor has three number of science laboratories and three rooms.

2nd block, 3rd block and 4th block: It is single storied building having three class rooms in each block. There is one window in each class rooms and the size are 7x6 feet. Two side of the window have provision to open.

5th block: It is single storied building having kitchen, dining hall, medical first aid room and library. Dining hall has 3 number of windows and three exits doors. The size of the window is 6x8 feet. Library and medical room have two windows in each room and the size is 6x8 feet. Two side of the window have provision to open.

6th **block:** It is two storied office building. In the ground floor there are staff room and section office room. There is one window in each room and the size is 7x6 feet. 1st floor has prayer room, Director room and Principal office.

<u>7th block:</u> It is single storied multipurpose hall. The size off the hall is 127x31 feet with 400 student sitting capacity. There are 5 number of windows and 4 number of exits doors. The size of the window is 5x5 feet.

There are 225 and 38 staffs.

The following Fire Safety equipment's which are installed in School Building:

- 07. 15 number of fire extinguisher ABC Type 4 kg capacity is installed in the school building.
- 08. 01 number of submersible bore in the premises of the school building.
- 09. 06 number of sand bucket is installed in the school premises.
- 10. 50 thousand liters underground reserve water tank is installed in the school premises.
- 11. 05 number of overhead tank 1000 liters capacity.
- 12. 02 number of yard hydrant are provided in the school premises fitted with high rated pump connected with underground water tank.

FIRE NOC is given in favour of Ladakh Rigjung Public School Chogiamsar, Len for period of One year from the issuance.

Director, F&ES, Ladakh PHQ, Agaling, Leh

Copy to:

- 01. Principal, Ladakh Rigjung Public school, Leh for information and n/a.
- 02. Superintendent of Police, F&ES, Ladakh for information.
- 03. Office file.